

November 18, 2025

City of Mercedes
ADDENDUM NO. 2025-005 (B)

Request for Proposals for
City Hall Floor Replacement Project

Prospective Proposers and all concerned are hereby notified of the following changes in the Request for Proposals document for the above-listed RFP. These changes shall be incorporated in and shall become an integral part of the RFP documents.

Closing Date to change:

From: Wednesday, November 19, 2025 @ 3:00 P.M.

To: Wednesday, December 3, 2025 @ 3:00 P.M.

SCOPE OF WORK / SPECIFICATIONS

1. Contractor is responsible for including in their bid complete scope of work which includes removing/re-installing existing materials and plumbing fixtures.
2. LVT flooring to be 20 mil.
3. Polish Concrete to be Class C 1/8-inch Semi-Gloss 45GU.

If you need additional clarification, you may contact Joselynn Castille at
jcastillo@cityofmercedes.com

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED IN THE BID PROPOSAL FORM.

End of Addendum